

MT9085 Series ACCESS Master

Release Notes

Version 1.04

Thank you for choosing the Anritsu MT9085 Series ACCESS Master.

This document explains the functions updated by firmware version 1.04 for the MT9085 Series ACCESS Master.

It also provides notes on known software issues and usage precautions.

Contents

Item	Description
1. Release Software and Manuals ...P3	Lists software and manuals included in this upgrade
2. Upgrade Target Models ...P3	Lists models supporting this firmware upgrade
3. Version Information ...P4	Lists software versions
4. New Features ...P5	Lists new functions
5. Resolved Software Issues ...P6	Lists improvements
6. Known Problems ...P6	Lists known problems
7. Cautions ...P7	Lists cautions for use of MT9085 Series
8. Upgrade Precautions ...P7	Provides important information

1. Release Software and Manuals

This upgrade contains the following MT9085 Series software and manuals.

Software	Version
MT9085 Series Firmware	1.04
Operation Manual	Edition
MT9085 Series ACCESS Master Operation Manual	4.0
MT9085 Series ACCESS Master SCPI Remote Control Operation manual	2.0
MT9085 Series ACCESS Master Quick Guide	3.0

2. Target Models

MT9085A, MT9085B, MT9085C

3. Version Information

This table shows the firmware version. Confirm the firmware version of your MT9085 Series ACCESS Master at the Setup Key and "About "screen.

Product Name	Version
MT9085 Series Firmware Update File	1.04

4. New Features

Function added and changed by v1.04

- None

Function added and changed by v1.03

- None

Function added and changed by v1.02

- Added a function that creates a summary of waveform files.
The summary of the waveform files (. SOR) can be saved in a text file.
For details, refer to Section 3.5.9 in the MT9085A Series ACCESS Master Operation Manual.
- Changed the display position of the Trace Overview.
The Trace Overview can now be displayed at "Lower Left" or "Upper Right".
Additionally, the height of the Trace Overview was adjusted.
- Changed the Overlay function
Even when there is only the primary trace, "Set to Overlay" is now available. If you execute this function after a measurement or after reading a waveform file, the measured waveform can be displayed as reference waveform.

Function added and changed by v1.01

- Added the function to display waveform enlarged.
Displaying the graph on the full screen is possible. Switching between normal display and enlarged display is possible by touching the icon on the left side of the graph.

- Added the function to set the color of the graph and background.
The setting "Background color and trace color" is added to "General" of setup. This enables selecting combination of background (white or black) and trace color (red, black or yellow).

- Changed the horizontal axis grid number of the graph.
The horizontal axis grid interval of the graph is narrower, and the number of displayed grids is increased. This makes visual evaluation of trace easier.

- Made it possible to perform Real time measurement in automatic mode.
Real-time measurement is possible not only manually but also automatically.

- Made it possible to perform measurement while displaying the measurement condition setting dialog.
When the measurement condition setting dialog is displayed, pressing Start or Realtime key fixes the setting and performs the measurement.

- Added the function to easily switch active waveform
"Next Trace" key is added to the second page of the function keys. Switching active trace by touching this key is possible.

- Added the function to hide the cursor.
Hiding the cursor at marker mode is possible. It is useful when taking screen capture only of waveform.

5. Resolved Software Issues

Model Name	Description
MT9085 Series ACCESS Master Ver. 1.04	Fixed a bug where MT9085A performed the measurement in Auto mode when pressing the Start key during the Realtime measurement even if the wavelength was set to "All" and the test mode was set to "Manual". (12457)
	Fixed a bug where the trace(s) measured in the Fiber Visualizer mode was displayed on the OTDR (Standard) trace screen when restarting MT9085A. (12059)
MT9085 Series ACCESS Master Ver. 1.03	Fixed a bug where the MT9085A may freeze when removing the Bluetooth dongle. (12302)
	Fixed a bug where the communication stops during the transfer of a large number of files via Bluetooth. (12253)
	Fixed a bug where file transfer cannot be performed after attempting the following procedure from the PC via Bluetooth. (12259) 1. In the File Explorer, open the MT9085 root folder (internal memory). 2. In the MT9085 root folder, open a sub folder. 3. Return to the MT9085 root folder.
	Fixed a bug where 0 byte data may be returned when sending the DAT? command continuously. (12247)
	Fixed a bug where MT9085 failed auto placement of markers on a waveform with no noise floor when Marker Mode was Placement. (12225)
MT9085 Series ACCESS Master Ver. 1.02	Fixed a bug where the battery/power icon was not updated immediately when the AC adapter was plugged in or unplugged in some instances. (11924)
	Fixed a bug where the unit of cursor distance was not displayed correctly in some instances. (12036)
	Fixed a bug where the SCPI command was executable without entering password. (12046)
	Fixed a bug where the Test Parameters screen was displayed incorrectly on Fiber Visualizer in some instances. (12052)
	Fixed a bug where "Set to all wavelengths" was displayed incorrectly on the parameter screen of all wavelength tests in some instances. (12051)
	Fixed a bug where the total loss was miscalculated in some instances. (12069)
	Fixed a bug where the average count was displayed incorrectly on Fiber Visualizer in some instances. (12071)
	Fixed a bug where an unnecessary log file was output to the USB memory stick in some instances. (12072)
	Fixed a bug where the "Local Operation" button was not operable while controlling with remote command in some instances. (12075)
	Fixed a bug where the vertical axis of the graph was displayed incorrectly in some instances. (12080)
MT9085 Series ACCESS Master Ver. 1.01	Fixed a bug where Markers 1, 2, 3 and 4 disappear when measuring with "wavelength" set to "all". (12029)
	Fixed a bug where markers were placed at inappropriate positions with "Put All" function and "Auto Marker" function. (11994, 11973)

6. Known Problems

Firmware version 1.04 for the MT9085 Series ACCESS Master contains the following known problems:

Model Name	Description
MT9085 Series ACCESS Master	➤ None

7. Cautions

Read the following terms and conditions carefully before using the MT9085 Series ACCESS Master.

Model Name	Description
MT9085 Series ACCESS Master	<ul style="list-style-type: none"> ➤ Some commercially available USB memory may not be supported. Refer to Section 8. Upgrade Precautions for details of USB memory supported by Anritsu. ➤ BEFORE upgrading the firmware, ALWAYS read the MT9085 Series ACCESS Master Firmware Upgrade Procedure and the MT9085 Series Operation Manual.

8. Upgrade Precautions

- Anritsu has confirmed compatibility with USB memory from the makers listed in the following table. If your USB memory is not recognized by the MT9085 Series ACCESS Master, please purchase one of the supported media types.

Manufacturer	Model/capacity
Biocryptodisk	ISPX/4GB
Sony	POCKET BIT/32MB
Sony	POCKET BIT 512MB Turbo
GREEN HOUSE	PicoDrive/64 MB
TOSHIBA	TransMemory/256 MB
TOSHIBA	TransMemory/512 MB
ADTEC	DATASTICK/64 MB
Princeton	X i a o Jr./64 MB
BUFFALO	RUF2 - E1G - B/512 MB
I-O DATA	ToteBag/512 MB
Scan Disk	Cruzer Micro with Skins USB Flash Drive/256 MB
imation	Flash Drive Mini with swivel cap/256 MB
Transcend	JetFlash/256 MB
Sony	POCKET BIT/8GB USM8GJ-B
I-O DATA	ToteBag/4GB TB-AT4G/B
BUFFALO	RUF2-J4GS-BK

- NEVER remove the USB memory inserted into the MT9085 Series ACCESS Master while updating, otherwise the firmware update will fail, leaving the MT9085 Series ACCESS Master unable to restart.
- When updating the firmware, do not press any key on the MT9085 Series ACCESS Master, otherwise the firmware update may fail, leaving the MT9085 Series ACCESS Master unable to restart.
- When updating the firmware, do not turn off the power to the MT9085 Series ACCESS Master, otherwise the firmware update will fail, leaving the MT9085 Series ACCESS Master unable to restart.
- When updating the firmware, do not remove the AC adapter plug from the MT9085 Series ACCESS Master, otherwise the firmware update may fail, leaving the MT9085 Series ACCESS Master unable to restart.

If the firmware update fails and the MT9085 Series ACCESS Master cannot restart, please contact our Anritsu sales representative.